

Water Testing Results - LCSD Water Testing for Lead

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Newport High West			
Room W27 Sink	Room W27	2/26/2021	ND
Room W29 Sink	Room W29	2/26/2021	ND
Room W31 Sink	Room W31	2/26/2021	ND
Room W31 Sink	Room W31 Lav	2/26/2021	ND
Room W33 Sink	Room W33	2/26/2021	ND
Room W34 Sink	Room W34	2/26/2021	ND
Room 11 C Sink	Room 11 C	2/26/2021	ND
Hall A Fountain/Bottle Filler	Hall A	2/26/2021	ND
Hall B Fountain/Bottle Filler	Hall B	2/26/2021	ND
Hall D Fountain/Bottle Filler	Hall D	2/26/2021	ND
Hall Sink	Hall Lav	2/26/2021	ND
Commons Area Fountain/Bottle Filler	Commons Area	2/26/2021	ND
Kitchen Bath Sink	Kitchen Bath Sink	2/26/2021	ND
N. Kitchen sink	N. Kitchen sink	2/26/2021	3.11
S. Kitchen Sink	S. Kitchen Sink	2/26/2021	3.35
S. Sink	S. Sink	2/26/2021	ND
E. Sink	E. Sink	2/26/2021	ND
N. Sink	N. Sink	2/26/2021	ND
Drinking Fountain	Drinking Fountain	2/26/2021	ND
N. Kitchen sink	N. Kitchen sink	3/19/2021	ND
S. Kitchen Sink	S. Kitchen Sink	3/19/2021	ND
Toledo Elementary			
Room 110 Sink	Room 110	3/26/2021	1.80
Room 110 Sink	Room 110	5/6/2021	ND
Crestview Height Elementary			
Commons Area Fountain/Bottle Filler	Commons Area	3/1/2021	ND
Hall A Fountain/Bottle Filler	Hall A	3/2/2021	ND

Hall B Fountain/Bottle Filler	Hall B	3/3/2021	ND
Hall C Fountain/Bottle Filler	Hall C	3/4/2021	ND
Room 11C Sink	Room 11C	3/5/2021	ND
Room 13 Sink	Room 13	3/6/2021	ND
Waldport High School			
Room 231B Sink	Room 231B	3/26/2021	8.13
Room 231B Sink	Room 231B	5/6/2021	3.62
ND = Non Detect - Lead level is below the set detection limits			of X ppb

|